

European Organisation for Technical Approvals Europäische Organisation für Technische Zulassungen Organisation Européenne pour l'Agrément Technique

ETAG 25

Edition May 2006

GUIDELINE FOR EUROPEAN TECHNICAL APPROVAL

OF

METAL FRAME BUILDING KITS

©EOTA, KUNSTLAAN 40 AVENUE DES ARTS, B - 1040 BRUSSELS

FOREWORD

Background to the subject

Reference documents

SECTION ONE: INTRODUCTION

- 1 PRELIMINARIES
- 1.1 LEGAL BASIS (to be finally written by EOTA Secretary general)
- 1.2 STATUS OF ETAG

2 SCOPE

- 2.1 SCOPE
- 2.2 USE CATEGORIES, PRODUCT FAMILIES, KITS AND SYSTEMS
- 2.3 ASSUMPTIONS

- 3 TERMINOLOGY
- 3.1 COMMON TERMINOLOGY AND ABBREVIATIONS
- 3.2 SPECIFIC TERMINOLOGY

SECTION TWO: GUIDANCE FOR THE ASSESSMENT OF THE FITNESS FOR USE

GENERAL NOTES

- (a) Applicability of the ETAG
- (b) General layout of this section
- (c) Levels or classes or minimum requirements, related to the essential requirements and to the product performance (see ID clause 1.2 and EC Guidance Paper E)
- (d) Working life (durability) and serviceability
- (e) Fitness for the intended use

4 REQUIREMENTS

- 4.1 MECHANICAL RESISTANCE AND STABILITY (ER 1)
- 4.2 SAFETY IN CASE OF FIRE (ER 2)
- 4.3 HYGIENE, HEALTH AND ENVIRONMENT (ER 3)
- 4.4 SAFETY IN USE (ER 4)
- 4.5 PROTECTION AGAINST NOISE (ER 5)
- 4.6 ENERGY ECONOMY AND HEAT RETENTION (ER 6)

5 METHODS OF VERIFICATION

- 5.1 MECHANICAL RESISTANCE AND STABILITY
- **5.2 SAFETY IN CASE OF FIRE**
- 5.3 HYGIENE, HEALTH AND ENVIRONMENT
- **5.4 SAFETY IN USE**
- 5.5 PROTECTION AGAINST NOISE
- 5.6 ENERGY ECONOMY AND HEAT RETENTION
- 5.7 DURABILITY, SERVICEABILITY AND IDENTIFICATION
 - 6 ASSESSING AND JUDGING THE FITNESS FOR USE
- **6.1 MECHANICAL RESISTANCE AND STABILITY**
- **6.2 SAFETY IN CASE OF FIRE**
- **6.3 HYGIENE, HEALTH AND ENVIRONMENT**
- **6.4 SAFETY IN USE**
- **6.5 PROTECTION AGAINST NOISE**
- **6.6 ENERGY ECONOMY AND HEAT RETENTION**
- 6.7 DURABILITY, SERVICEABILITY AND IDENTIFICATION
 - 7 ASSUMPTIONS AND RECOMMENDATIONS UNDER WHICH THE FITNESS FOR USE OF THE METAL FRAME BUILDING KIT IS ASSESSED
- 7.0 GENERAL
- 7.1 DESIGN OF THE WORKS
- 7.2 TRANSPORT, STORAGE
- 7.3 EXECUTION OF WORKS
- 7.4 MAINTENANCE AND REPAIR

SECTION THREE: ATTESTATION OF CONFORMITY (AC)

- 8 EVALUATION AND ATTESTATION OF CONFORMITY AND CE MARKING
- **8.1 SYSTEM OF ATTESTATION OF CONFORMITY**
- 8.2 TASKS AND RESPONSIBILITIES OF THE MANUFACTURER AND NOTIFIED BODIES
- **8.3 CE MARKING AND ACCOMPANYING INFORMATION**

SECTION FOUR: ETA CONTENT

- 9 THE ETA CONTENT
- 9.1 THE ETA CONTENT
- 9.2 ADDITIONAL INFORMATION

ANNEX A

COMMON TERMINOLOGY AND ABBREVIATIONS

ANNEX B

LIST OF REFERENCE DOCUMENTS

FOREWORD

Background to the subject

This Guideline has been drawn up by EOTA Working Group 02.04/01b – Metal Frame Building Kits.

The Working Group consisted of members from 6 EEC-countries; Belgium, Finland, Germany, Ireland, Netherlands (convenorship) and United Kingdom. There were observers from Slovakia and Slovenia.

The guideline sets out the performance requirements for metal frame building kits used in building construction, the verification methods used to examine the performance, the assessment methods used to evaluate the performance for the intended use, and the presumed conditions for the design and installation of the kits in the works.

Metal frame building kits according to this guideline are construction products defined in the Mandate (ref Construct 01/505, as amended after written consultation) as follows:

This mandate covers those industrially prepared kits, marketed as a building, that are made of pre-designed and prefabricated components intended for production in series. This mandate defines minimum requirements on the contents of such a kit. Partial kits falling below these minimum requirements are outside the scope of this mandate and shall not be CE marked on the basis of the resulting ETAG. These minimum requirements comprise all of the following: the structural elements of the building (walls, columns, beams, floors, roofs), the connection of the building to the substructure and the specification of the essential components of the external envelope such as thermal insulation, cladding, roof covering, internal lining, windows and external doors in so far as they are necessary for the satisfaction of the Essential Requirements applied to the building.

The design process (including the approval of detailed plans, applications for planning permission, building permits, ...) must comply with the procedures foreseen in the Member States in which the house is to be built. This Mandate does not amend this process in any way. The completed building (the works) must comply with the building regulations (regulations on works) applicable in the Member States in which the building is to be constructed. The procedures foreseen in that Member State for demonstrating compliance with the building regulations must also be followed by the entity held responsible for this act. This mandate does not amend this process in any way.

Although some components may be prepared in different factories, only the final kit for delivery, and not the different components, can be CE marked as a whole, under the responsibility of the ETA Holder.

The declared performance of the kit shall be compared with the relevant requirements in the building regulations from case to case, taking into account the intended use of the kit in relation to type of building, site, etc. An ETA is a favourable technical assessment of a construction product for an intended use, i.e. incorporated in the works. The ETA deals only with the product, and states classes or product characteristics to be used by the designer of the works.

Verification and assessment methods of loadbearing performance are based on the provisions in relevent Eurocodes.

Verification and assessment methods of performance in relation to fire is based on the publication of European standards concerning classification for reaction to fire and resistance to fire.

Verification of the performance of metal frame building kits requires an assessment of many construction details, such as the performance of joints between prefabricated elements with respect to air permeability and durability, the strength of lining materials with respect to impact loads and safety in use, watertightness of internal wet areas, etc. Relevant standardised verification methods may not always be available or judged to be necessary since the performance of many construction details has been proven to be acceptable by long-term experience from use in traditional designs. In accordance with the general advice in the Format of Guidelines for ETA's it is recognised in this guideline that some product properties can be assessed by a pass/fail approach on the basis of engineering judgement and experience from the use of well-known materials and designs.

Reference documents

Reference documents are referred to within the body of the ETAG and are subject to the specific conditions mentioned therein. ENV's and prEN's are referred to within this ETAG. When ENV's or prEN's are replaced, the latest version shall be used.

The **list of reference documents** (mentioning the year of issue) for this ETAG is given in annex B. When additional parts for this ETAG are written afterwards, they may comprise modifications to the list of reference documents applicable to that part.

Updating conditions

The edition of a reference document given in this list is that which has been adopted by EOTA for its specific use.

When a new edition becomes available, this supersedes the edition mentioned in the list only when EOTA has verified or re-established (possibly with appropriate linkage) its compatibility with the guideline.

EOTA Technical Reports go into detail in some aspects and as such are not part of the ETAG but express the common understanding of existing knowledge and experience of the EOTA-bodies at that moment. When knowledge and experience is developing, especially through approval work, these reports can be amended and supplemented.

EOTA Comprehension Documents permanently take on board all useful information on the general understanding of this ETAG as developed when delivering ETA's in consensus by the EOTA members. Readers and users of this ETAG are advised to check the current status of these documents with an EOTA member.

EOTA may need to make alterations/corrections to the ETAG during its life. These changes will be incorporated into the official version on the EOTA website www.eota.be and the actions catalogued and dated in the associated **History File**.

Readers and users of this ETAG are advised to check the current status of the content of this document with that on the EOTA website. The front cover will indicate if and when amendment has taken place.

SECTION ONE: INTRODUCTION

1 PRELIMINARIES

1.1 LEGAL BASIS (TO BE FINALLY WRITTEN BY EOTA SECRETARY GENERAL)

This ETA Guideline has been established in compliance with the provisions of the Council Directive 89/106/EC and has been established taking into account the following steps:

- the final mandate issued by the EC

:03/02/2003

- the final mandate issued by EFTA

:03/02/2003

- adoption of the Guideline by the Executive Commission of EOTA

:November 2005

- opinion of the Standing Committee for Construction

:@@/@@/@@

- endorsement by the EC

This document is published by the Member states in their official language or languages according to art. 11/3 of the CPD. No existing ETA guideline is superseded.

1.2 STATUS OF ETAG

- a. **An ETA** is one of the two types of technical specifications in the sense of the EC 89/106 Construction Products Directive (89/106/EEC). This means that Member States shall presume that the approved metal frame building kits are fit for their intended use, i.e. they enable works in which they are employed to satisfy the essential requirements during an economically reasonable working life, provided that:
- the works are properly designed and built:
- the conformity of the products with the ETA has been properly attested.
- b. **This ETAG** is a basis for ETA's, i.e. a basis for technical assessment of the fitness for use of a product for an intended use. An ETAG is not itself a technical specification in the sense of the CPD.

This ETAG expresses the common understanding of the approval bodies, acting together within EOTA, as to the provisions of the Construction Products Directive 89/106 and of the Interpretative Documents, in relation to the metal frame building kits and uses concerned, and is written within the framework of a mandate given by the Commission and the EFTA secretariat, after consulting the Standing Committee for Construction.

c. When accepted by the European Commission after consultation with the Standing Committee for Construction this **ETAG** is binding for the issuing of ETA's for metal frame building kits for the defined intended uses.

The application and satisfaction of the provisions of an ETAG (examinations, tests and evaluation methods) leads to an ETA and a presumption of fitness of a metal frame building kit for the defined use only through an evaluation an approval process and decision, followed by the corresponding attestation of conformity. This distinguishes an ETAG from a harmonised European standard which is the direct basis for attestation of conformity.

Where appropriate, metal frame building kits which are outside of the precise scope of this ETAG may be considered through the approval procedure without guidelines according to art. 9.2 of the CPD.

The requirements in this ETAG are set out in terms of objectives and of relevant actions to be taken into account. It specifies values and characteristics, the conformity with which gives the presumptions that the requirements set out are satisfied, wherever the state of art permits and after having been confirmed as appropriate for the particular product by the ETA.

This guideline indicates alternative possibilities for the demonstration of the satisfaction of the requirement.

2 SCOPE

2.1 SCOPE

This guideline covers those industrially prepared metal frame systems, marketed as kits, that are made of pre-designed and prefabricated components intended for production in series.

The components in a kit may be manufactured as metal members (such components should be in accordance with the relevant EN) or structural frames or as completely prefabricated building elements (excluding volumetric units/3-dimensional and cold storage building kits). The content of the kit is dominately of metal structural components but may include non-metal structural components. A kit may comprise only the load bearing components of a structure. In such cases any restrictions in methods and locations of the connections of the external envelope, the ground floor and roof needs to be identified and be part of the ETA.

Metal members may be manufactured of steel, galvanic steel, stainless steel or aluminium.

The minimum content of the kit to be assessed shall include the following, as far as is necessary for the satisfaction of the Essential Requirements applied to the building: the structural components of the building (walls, columns, beams, floors, roofs), the connection of the building to the substructure and the specification of the essential components of the external envelope such as thermal insulation, cladding, roof covering, internal lining, windows and external doors (see note).

The kits are assembled according to pre-designed technical solutions for joints between the structural components and construction details.

Products like the external envelope as thermal insulation, cladding, roof covering, internal lining, internal partitions, windows and doors, stairs, surface coverings etc. may be part of the metal frame kit. Service installations and complementary structures (including foundation or substructure) are not covered by this ETA Guideline.

Partial kits which do not meet all the conditions set out above are outside this scope, and shall not be CE-marked on the basis of an ETA based on this Guideline.

Although some components may be prepared in different factories, only the final kit for delivery, and not the different components, can be CE marked as a whole, under the responsibility of the ETA holder.

Note

The external envelope, the ground floor and the roof do not have to be part of the kit. This means that only the loadbearing structure of a building consisting of walls, columns, beams and/or floors can considered as a kit under this ETAG.

2.2 USE CATEGORIES, PRODUCT FAMILIES, KITS AND SYSTEMS

The product performance of metalframe building kits in relation to the Essential Requirements will normally be required to correspond with national regulatory requirements for the works relevant to the intended use of the product in, for example, dwellings, office buildings, schools, hospital and medical buildings, dormitories¹. These requirements will vary between the member states, and the product performance shall be expressed in numerical terms. For performance in case of fire, standard European fire classification is applied.

2.3 ASSUMPTIONS

The state of the art does not enable the development, within a reasonable time, of full and detailed verification methods and corresponding technical criteria/guidance for acceptance for some particular aspects and products. This ETAG contains assumptions taking account of the state of art and makes provisions for appropriate, additional case by case approaches when examining ETA-applications, within the general framework of the ETAG and under the CPD consensus procedure between EOTA members.

The guidance remains valid for other cases which do not deviate significantly. The general approach of the ETAG remains valid, but the provisions then need to be used case by case in an appropriate way. This use of the ETAG is the responsibility of the ETA-body which receives the special application, and subject to consensus within EOTA. Experience in this respect is collected, after endorsement in EOTA-TB, in the ETAG-Format-Comprehension document.

¹ List not exhaustive.

3 TERMINOLOGY

3.1 COMMON TERMINOLOGY AND ABBREVIATIONS

See Annex A.

3.2 SPECIFIC TERMINOLOGY

In this paragraph the specific terminology used in this ETAG is given in alphabetical order. These terminology is additional to the terminology used and defined in the European standards to which is referred in this ETAG.

Design climatic conditions:

Outdoor and indoor air temperature and moisture levels, snow loads, wind speed levels, etc, which may be stated in national building regulations or in other specifications to be used for design.

Integrated components:

Components such as windows, non-load bearing elements for external envelope, doors, conduits, etc which are built into the main building parts.

Internal partitions:

Partitions according to ETAG 003.

Joint/Connection:

Junction between two materials, components, elements or parts of a building.

Main building parts:

Main construction parts of a building like walls, floors and roof.

Metal frame building:

Building of which the structure is mainly made of structural metal components such as walls, columns, beams, floors and roofs.

National Application Document:

Supplementary document to a structural Eurocode published as European prestandard (ENV), with rules for the national application of the Eurocode. This includes boxed values and references to national standards which may be applied together with the provisions in the Eurocode.

Nationally Determined Parameter (NDP)

A National choice left open in a EN Eurocode about values (where symbols are given in the EN Eurocodes), classes or alternative procedures permitted within the EN Eurocodes.

Pre-designed:

Pre-determined technical solutions.

Production in series:

Production of building kits on the basis of the same materials, structural design and construction details. The buildings and components do not have to be exactly of the same size or shape.

Production unit:

Production line or facility where the metal frame kit is manufactured and/or processed.

Separating walls and floors:

Walls and floors where national regulations can require sound insulation, fire resistance performance, etc.

Supporting documents:

Documents included in the formal part of the approval, but where the content is not included in the ETA-document itself. The valid version of a supporting document is the last updated version filed by the approval body.

Suspended floors:

Floor structures with a free span between supports.

Structure

Load-bearing construction, i.e. organised assembly of connected parts designed to provide mechanical resistance and stability to the works (ID 1, clause 2.1.1).

Structural material

Material or constituent product with properties which enter into structural calculations or otherwise relate to the mechanical resistance and stability of works and parts thereof, and/or to their fire resistance, including aspects of durability and serviceability.

Structural component

Load-bearing part of Works designed to provide mechanical resistance and stability to the works and/or fire resistance, including aspects of durability and serviceability, (ID 1, clause 2.1.1).

Two-stage principle:

Design principle for claddings, joints, etc in the exterior envelope. An outer layer serves to protect an inner layer from direct driving rain and sun radiation. The space between the layers is ventilated and drained.

Wet area surface:

Floors and wall areas in bathrooms and other "wet rooms" where the surface may be exposed to water spray from showers, etc, and where the manufacturer declares the surfaces to be watertight.

SECTION TWO: GUIDANCE FOR THE ASSESSMENT OF THE FITNESS FOR USE

GENERAL NOTES

(a) Applicability of the ETAG

This ETAG provides guidance on the assessment of a family of metal frame building kits and their intended uses. It is the manufacturer or producer who defines the family of kits for which he is seeking an ETA and how it is to be used in the works, and consequently the scale of the assessment.

It is therefore possible that for some metal frame building kits, which are fairly conventional, only some of the tests and corresponding criteria are necessary to establish fitness for use. In other cases, e.g. special or innovative kits or materials, or where there is a range of uses, the whole range of tests and assessment may be applicable.

(b) General layout of this section

The assessment of fitness of metal frame building kits with regard to their fitness for intended use in construction works is a process with three main steps:

- Chapter 4 clarifies the specific requirements for the works relevant to the metal frame building kits and uses concerned, beginning with the Essential Requirements for works (CPD art. 11.2) and then listing the corresponding relevant characteristics of the metal frame building kits.
- Chapter 5 extends the list in chapter 4 into more precise definitions and the methods
 available to verify product characteristics and to indicate how the requirements and the
 relevant product characteristics are described. This is done by test procedures, methods of
 calculation and other appropriate methods.
- Chapter 6 provides guidance on the assessing and judging methods to confirm fitness for the intended use of the metal frame building kits.
- Chapter 7, assumptions and recommendations are only relevant in as far as they concern
 the basis upon which the assessment of the metal frame building kits is made concerning
 their fitness for the intended use.

(c) Levels or classes or minimum requirements, related to the essential requirements and to the product performance (see ID clause 1.2 and EC Guidance Paper E)

According to the CPD "Classes" in this ETAG refer only to mandatory levels or classes laid down in the EC-mandate.

This ETAG indicates however the compulsory way of expressing relevant performance characteristics for metal frame building kits. If, for some uses at least one Member state has no regulations, a manufacturer always has the right to opt out one or more of them, in which case the ETA will state "no performance determined" against that aspect, except for those properties for which, when no determination has been made, the metal frame building kit does not any longer fall under the scope of the ETAG; such cases shall be indicated in the ETAG.

(d) Working life (durability) and serviceability

The provisions, test and assessment methods in this guideline or referred to, have been written, based upon the assumed intended working life of the metal frame building kit for the intended use of 50 years for the loadbearing structure and for non-accessible components and materials, and 25 years for repairable or replaceable components and materials like claddings, roofing materials, exterior trims, and integrated components like windows and doors, provided that the kit is subject to appropriate use and maintenance (see chapter 7). The use of components and materials with shorter intended working life shall be clearly stated in the ETA. These provisions are based upon the current state of art and the available knowledge and experience.

An "assumed intended working life" means that it is expected that, when an assessment following the ETAG-provisions is made, and this working life has elapsed, the real working life may be, in normal use conditions, considerably longer without major degradation affecting the essential requirements.

The indications given as to the working life of a metal frame building kit can not be interpreted as a guarantee given by the producer or the approval body. They should only be regarded as a means for the specifiers to choose the appropriate criteria for metal frame building kits in relation to the expected, economically reasonable working life of the works (based upon ID. Par. 5.2.2).

(e) Fitness for the intended use

According to the CPD it has to be understood that within the terms of this ETAG, products shall "have such characteristics that the works in which they are to be incorporated, assembled, applied or installed, can, if properly designed and built, satisfy the Essential Requirements" (CPD, art. 2.1).

Hence, the metal frame building kits shall be suitable for use in construction works, in which (as a whole and in their separate parts) they are fit for their intended use, account being taken of economy, and in order to satisfy the essential requirements. Such requirements shall, subject to normal maintenance, be satisfied for an economically reasonable working life. The requirements generally concern actions which are foreseeable (CPD Annex 1, preamble).

4 REQUIREMENTS

This chapter sets out the aspects of performance to be examined in order to satisfy the relevant Essential Requirements, by:

- expressing in more detail, within the scope of the ETAG, the relevant Essential
 Requirements of the CPD in the Interpretative Documents and in the mandate, for works
 or parts of the works, taking into account the actions to be considered, as well as the
 expected durability and serviceability of the works.
- applying them to the scope of the ETAG (product and where appropriate its constituents, components and intended uses), and providing a list of relevant product characteristics and other applicable properties.

When a product characteristic or other applicable property is specific to one of the Essential Requirements, it is dealt with in the appropriate place. If, however, the characteristic or property is relevant to more than one Essential Requirement, it is addressed under the most important one with cross reference to the other(s). This is especially important where a manufacturer claims "No performance determined" for a characteristic or property under one Essential Requirement and it is critical for the assessing and judging under another Essential Requirement. Similarly, characteristics or properties which have a bearing on durability assessments may be dealt with under ER 1 to ER 6, with reference under 4.7. Where there is a characteristic which only relates to durability, this is dealt with in 4.7.

This chapter also takes into account further requirements, if any (e.g. resulting from other EC Directives), and identifies aspects of serviceability including specifying characteristics needed to identify the products (cfr. ETA-format par. II.2).

Table 1 on the next page shows the links between the Essential Requirements in the EC Construction Products Directive (CPD), the relevant paragraphs of the corresponding Interpretative Documents (ID) to the CPD, and the related requirements and product performances in this ETA Guideline.

Table 1 – Links between the ER, relevant paragraphs of the ID and requirement and product performances in this ETAG

	performances in this ETAG		T =
	Corresponding	Corresponding	Product performance
ER	ID paragraph	ID paragraph for	characteristics from the Mandate,
	for works	product performance	and ETA-Guideline paragraphs on
			product performance
1	2.1.3	3.2 (2)	4.1 - Mechanical resistance and
	Collapse	Permanent actions	stability
		Variable actions	
	2.1.4	Accidental actions	
	Inadmissible deformation		
	2.1.5		
	Damage by an event to an		
	extent disproportionate to the		
	original cause		
2	4.2.2	4.3.1.1	4.2 - Safety in case of fire
	Load bearing capacity of the	Products subject to reaction to	
	construction	fire requirements	4.2.1 Reaction to fire
	4.2.3	4.3.1.2	4.2.2 Resistance to fire
	Limitation of generation and	Products for roofs subject to	
	spread of fire and smoke within	fire requirements	4.2.3 External fire performance (of the
	the construction works		roof covering)
	4.2.4	4.3.1.3	4.2.4 Fire compartmentation
	Limitation of spread of fire to	Products subject to resistance	
	neighbouring construction	to fire requirements, load-	
	works	bearing elements with or	
		without separating function	
3	3.3.1.1	3.3.1.1.3.2 a	4.3 - Hygiene, health and environment
	Air quality	Emission and release of	
		radiation and pollutants.	4.3.1 Vapour permeability and
	3.3.1.2	Susceptibility to the growth of	moisture resistance
	Dampness	harmful micro-organisms	40004 4 6 4
	(indirect effect inducing mould-	004000	4.3.2 Watertightness
	growth and increased deposit	3.3.1.2.3.2 e	4.2.2 Dologo of dommer
	of house dust mites)	Building products	4.3.3 Release of dangerous
<u></u>	0.04.0	0.04.0	substances
4	3.3.1.2	3.3.1.3	4.4 - Safety in use
	Falling after slipping.	Falling after slipping	4.4.1 Slipperiness of floor finishes
	Falling due to changes in level	Falling due to changes in level	4.4.3 Falling due to changes in level
	or sudden drops.	or sudden drops.	or sudden drops.
	222	2 2 2 2	4.4.2 Decistores to accompain lead-
	3.3.2.	3.3.2.3 Mechanical resistance and	4.4.2 Resistance to eccentric loads
	Behaviour on impact		including impact resistance.
5	2.3.1, 2.3.2, 2.3.3	stability 4.3.2	4.5. Protection against noise
٥		4.3.2 Acoustic properties	4.5 - Protection against noise
	Protection against air-borne and impact noise between	(according to 4.3.3)	4.5.1 Airborne sound insulation
	and impact noise between enclosed spaces and from	(according to 4.3.3)	4.5. FAIIDOTTIE SOUND INSUIATION
	outside of works		4.5.2 Impact sound insulation
	Catalac of works		7.0.2 Impact sound insulation
			4.5.3 Sound absorption
6	4.2	Table 4.2	4.6 - Energy economy and heat
"	Energy consumption limitation	Component characteristics	retention
	Livery consumption initiation	Component onaracteristics	Totolidoli
			4.6.1 Thermal resistance
			1.0.1 Indinial registance
			4.6.2 Air permeability
			7 th pormoubling
			4.6.3 Thermal inertia
L	1		1.0.0 Hiomiai inorda

4.1 MECHANICAL RESISTANCE AND STABILITY (ER 1)

The metal frame building kit shall be capable of supporting the specified loadings with adequate safety against structural collapse, inadmissible deformations and where applicable disproportionate collapse. The relevant actions to be considered normally comprise self-weight and imposed loads, wind loads, snow loads and, where appropriate, seismic loads.

4.2 SAFETY IN CASE OF FIRE (ER 2)

The Essential Requirement laid down in the Council Directive 89/106/EEC is as follows:

The construction works shall be designed and built in such a way that in the event of an outbreak of fire:

- 1. the load bearing capacity of the construction can be assumed for a specific period of time;
- 2. the generation and spread of fire and smoke within the works are limited;
- 3. the spread of fire to neighbouring construction works is limited;
- 4. occupants can leave the works or be rescued by other means;
- 5. the safety of rescue teams is taken into consideration.

The following aspects of performance are relevant to the Essential Requirements for metal frame building kits:

4.2.1 Reaction to fire

The reaction to fire performance of the individual kit components shall be in accordance with laws, regulations and administrative provisions applicable to these individual kit components of the metal frame building kit in its intended and use application. This performance shall be expressed in the form of a classification specified in accordance with the relevant EC decision and the appropriate CEN classification standards.

4.2.2 Resistance to fire

The resistance to fire performance of the assembled components of the metal frame building kit (e.g. wall, floor or roof) shall be in accordance with laws, regulations and administrative provisions applicable to these assembled components in its intended and use application. This performance shall be expressed in the form of a classification specified in accordance with the relevant EC decision and the appropriate CEN classification standards.

4.2.3 External fire performance of the roof covering

The external fire performance of the roof covering of the metal frame building kits shall be in accordance with laws, regulations and administrative provisions applicable to the roof covering in its intended end use application. This performance shall be expressed in the form of a classification specified in accordance with the relevant EC decision and the appropriate CEN classification standards.

4.2.4 Fire compartmentation

The fire compartmentation of an assembled building shall be in accordance with laws, regulations and administrative provisions applicable to the works where the building is to be constructed.

4.3 HYGIENE, HEALTH AND ENVIRONMENT (ER 3)

4.3.1 Vapour permeability and moisture resistance

The properties of the kit shall be such that there will be no threat to the occupants or neighbours due to the presence of damp in the works or on surfaces within the works formed from the kit.

4.3.2 Watertightness

4.3.2.1 External envelope

The external envelope shall prevent leakage of water from rain and melting snow into the works.

4.3.2.2 Internal surfaces

Internal wall and floor surfaces in bathrooms, toilets, etc claimed to be watertight by the manufacturer, shall be sufficiently tight to avoid water penetration to rooms below (short-term effects) and to avoid moisture levels in materials and components which may lead to unacceptable growth of micro-organisms (long-term effects).

4.3.3 Release of dangerous substances

The kit shall be such that, when installed according to the appropriate provisions of the Member States, it allows for the satisfaction of the ER3 of the CPD as expressed by national provisions of the Member States and in particular does not cause harmful emissions of toxic gases, dangerous particles or radiation to the indoor environment nor contamination of the outdoor environment (air, soil or water).

4.4 SAFETY IN USE (ER 4)

4.4.1 Slipperiness of floor finishes

To limit accidental falls in buildings under normal use, finished floor surfaces shall not be unacceptably slippery and any unexpected change of slipperiness of the floor surfaces shall be avoided.

4.4.2 Resistance to eccentric and impact loads

The metal frame building kits shall have sufficient mechanical resistance and stability to ensure that the safety of the occupants is not endangered (See also ER 1). This means that they shall have sufficient mechanical resistance and stability to withstand accidentally large static or dynamic loads, from the action of persons or objects, without full or partial collapse causing dangerous (sharp or cutting) fragments, giving risk of falling through, particularly at a change of level, or endangering the safety of other people.

The loads may be in the form of:

- · impacts resulting from a person falling against the wall;
- differential air pressure;
- a large number of people leaning or pressing against the wall at the same time (crowd pressure);
- impacts resulting from the movement of heavy non-deformable objects such as pieces of furniture or equipment;
- slamming of doors;
- heavy objects such as furniture and sanitary or heating equipment.

4.4.3 Falling due to changes in level or sudden drops

To protect persons against falling appropriate guard-rails, balustrades, parapets should be used to cover accessible openings, appropriate stairways, fixed ladders, ramps should be used by changes in levels, appropriate safety catches and hinges should be used in windows in upper storeys.

4.5 PROTECTION AGAINST NOISE (ER 5)

4.5.1 Airborne sound insulation

Walls and floors shall provide the necessary airborne sound insulation applicable to the intended use of the building.

The external envelope shall provide the necessary sound insulation applicable to the intended use of the building concerning airborne noise from the outside (i.e. noise from industry, road and air traffic, etc).

4.5.2 Impact sound insulation

Floors shall provide the necessary impact sound insulation applicable to the intended use of the building.

4.5.3 Sound absorption

The internal surfaces which are part of the kit shall provide the necessary sound absorption applicable to the intended use of the building.

4.6 ENERGY ECONOMY AND HEAT RETENTION (ER 6)

4.6.1 Thermal resistance

The external envelope shall provide the necessary thermal insulation which is applicable to the intended use of the building. Thermal bridges which may cause uncomfortably low temperatures or water vapour condensation affecting hygiene, health and environment related to ER 3 shall be avoided.

4.6.2 Air permeability

The external envelope shall provide adequate airtightness to limit unnecessary energy loss, and to prevent cold draughts which may affect persons health in relation to ER 3.

4.6.3 Thermal inertia

Thermal inertia of the main building parts shall be known, where applicable, to assess the effect on energy and heat retention.

4.7 ASPECTS OF DURABILITY, SERVICEABILITY AND IDENTIFICATION

4.7.1 Aspects of durability

The design of the metal frame building kit shall ensure that deterioration of materials and components during the assumed intended working life does not significantly affect the performance of the kit in relation to fulfilling all the Essential Requirements 1 – 6. Deterioration may be caused by physical, biological and chemical agents.

4.7.2 Aspects of serviceability

Loadbearing elements shall have sufficient stiffness to avoid unacceptable deflections and dynamic effects from normal use.

4.7.3 Identification

The materials used in the metal frame building kit shall be identifiable in relation to those properties which have an influence on the ability of the kit to fulfil the Essential Requirements.

5 METHODS OF VERIFICATION

This chapter refers to the verification methods used to determine the various aspects of performance of the metal frame kit in relation to the requirements for the works (calculations, tests, engineering knowledge, site experience etc.) as set out in chapter 4. For the acceptance criteria of data (e.g. test reports) see EOTA GUIDANCE DOCUMENT 004 "The Provisions of Data for Assessments Leading to ETA".

When EUROCODES are quoted in this ETAG as the methods for the verification of certain product characteristics, their application in this ETAG, as well as in the subsequent ETA's issued according to this ETAG, shall be in accordance with the principles laid down in the EC Guidance Paper L on the use of EUROCODES in harmonised European technical specifications (Option 1, 2 or 3).

When the performance is assessed by reference to traditional methods, general experience, etc., the Technical Dossier of the ETA shall as far as possible refer to documents where such methods or experience are described.

Assessment of individual materials and components which are part of the kit and their assessment into the works shall be carried out on the basis of the relevant product standards or approvals for these products, or as far as possible on the basis of technical specifications for products with the same intended use.

The relationship between the product performance characteristics and the corresponding paragraphs on verification methods are summarised in Table 2.

Table 2 - The relationship between the product performance characteristics and the corresponding paragraphs on verification methods

ER	ETAG paragraph on	ETAG paragraph on	
	product performance	verification method	
1	4.1	5.1	
	Mechanical resistance and stability	Mechanical resistance and stability	
		5.1.1	
		Verification of structural	
		capacities in general	
		5.1.2	
		Verification by calculation	
		5.1.3	
		Verification by testing	
2	4.2	5.2	
	Safety in case of fire	Safety in case of fire	
	4.2.1	5.2.1	
	Reaction to fire	Reaction to fire	
	4.2.2	5.2.2	
	Resistance to fire	Resistance to fire	
	4.2.3	5.2.3	
	External fire performance	External fire performance	
	of the roof covering	of the roof covering	
	4.2.4	5.2.4	
	Fire compartmentation	Fire compartmentation	

ER	ETAG paragraph on product performance	ETAG paragraph on verification method
3	4.3 Hygiene, health and environment 4.3.1	5.3 Hygiene, health and environment 5.3.1
	Vapour permeability and moisture resistance	Vapour permeability and moisture resistance
	4.3.2 Watertightness	5.3.2.1 External envelope 5.3.2.2 Internal surfaces
	4.3.3 Release of dangerous substances	5.3.3 Release of dangerous substances
4	4.4 Safety in use	5.4 Safety in use
	4.4.1 Slipperiness of floors	5.4.1 Slipperiness of floors
	4.4.2 Impact resistance	5.4.2 Impact resistance
	4.4.3 Falling due to changes in level or sudden drops	5.4.3 Falling due to changes in level or sudden drops
5	4.5 Protection against noise	5.5 Protection against noise
	4.5.1 Airborne sound insulation	5.5.1 Airborne sound insulation
	4.5.2 Impact sound insulation 4.5.3	5.5.2 Impact sound insulation 5.5.3
	Sound absorption	Sound absorption
6	4.6 Energy economy and heat retention	5.6 Energy economy and heat retention
	4.6.1 Thermal resistance	5.6.1 Thermal resistance
	4.6.2 Air permeability	5.6.2 Air permeability
	4.6.3 Thermal inertia	5.6.3 Thermal inertia

5.1 MECHANICAL RESISTANCE AND STABILITY

5.1.1 Verification of structural capacities in general

The structural components, and the structure and the connections shall be verified in conformity with the basis of design as given in EN 1990:2002, e.g. according to the limit state design method.

Consideration should be given to the relevant actions on structures as defined EN 1991. The verification can normally be undertaken by structural calculations, supplemented if necessary by testing in special cases, and shall when relevant include resistance against disproportionate collapse.

5.1.2 Verification by calculation

Calculations should be made according to the relevant parts of EN 1993 to verify that the steel structural components and the steel structure do not exceed the relevant ultimate state.

Calculations should be made according to the relevant parts of the ENV 1999 to verify that the aluminium structure and its components do not exceed the relevant ultimate state.

If other structural materials are used for the elements, the relevant parts of the following Eurocodes should be used:

- EN 1992-1 for concrete;
- EN 1994-1 for composite steel-concrete;
- EN 1995-1 for timber elements.

Supplementary calculations which are relevant for the resistance against seismic actions should be done according to the provisions in EN 1998, for various materials and elements. Other information on capacities against seismic actions based on the various values given in Nationally Determined Parameters (NDP's) or other national regulations may be undertaken as a basis for the specific structural design for each individual work.

5.1.3 Verification by calculation assisted by testing

Where calculations rules or material properties given in the EN's according to 5.1.2 are not sufficient or where economy may result from tests on prototypes, part of the design procedure may be performed on the basis of tests. In general this design assisted by testing shall be done according to EN 1990. The test methods for the determination of mechanical properties shall be specified. Furthermore the requirements for the factory production control and for the conformity attestation shall be specified. This shall be done in such a way that each declared value or declared class corresponds to a defined statistical confidence (defined fractile and confidence level) and can, for structural design of works, be taken as the "characteristic value" or "design value".

Test methods which are described in (h-)EN's, ETAG's or ISO-standards for materials and components which are used/part of the kit may be used.

Because the current state of the art is that very few test methods exist, the following procedure enables the use of new test methods (see also § 2.3):

- The approval body which needs to use a test method for issuing an ETA, makes a proposal for this test method and sends it to EOTA;
- The test method can be developed as EOTA Technical Report and will be agreed by the EOTA technical board:
- Reference to this test method shall be made in the progress file of the ETAG;
- The test method become then part of the ETAG and the Approval Body may use the test method.

5.2

5.2 SAFETY IN CASE OF FIRE

The fire performance of any product in terms of either reaction to fire, fire resistance and/or external fire performance, as considered in the following sections, does not only depend upon its intrinsic properties and the nature of the thermal attack, but also on its situation when incorporated into works. The testing of products (or the assembled system of which the product forms part) shall be such as to simulate the product in its intended end use application(s).

5.2.1 Reaction to fire

Generally, one or more of the following options shall apply.

Option 1: Products not covered by options 2 or 3.

The individual kit components shall be tested, using the test method(s) relevant for the corresponding reaction to fire class, in order to be classified according to EN 13501-1.

Option 2: Products satisfying the requirements for the fire reaction class A1, without the need for testing

The individual kit components are considered to satisfy the requirements for performance Class A1 of the characteristic reaction to fire, in accordance with the provisions of EC Decision 96/603/EC (as amended) without the need for testing on the basis of its listing in that Decision.

Option 3: Products classified without the need for further testing (CWFT)

The individual kit components are considered to satisfy the requirements for performance Class of the characteristic reaction to fire in accordance with the relevant EC Decision without the need for testing on the basis of its conformity with the specification of the product detailed in that Decision and its intended end use application being covered by that Decision.

5.2.2 Resistance to fire

The assembled components of the metal frame building kit (e.g. wall, floor or roof) shall be tested, using the test method relevant for the corresponding fire resistance class, in order to be classified according to the appropriate part of EN 13501. Structural resistance in case of fire may also be determined from the relevant Eurocode.

Fire resistance performance cannot be claimed for individual products alone, since it is a characteristic of a complete component.

5.2.3 External fire performance of the roof covering

Generally, one or more of the following options shall apply.

Option 1: Products not covered by options 2 or 3.

The roof covering shall be tested using the test method relevant for the corresponding external fire performance roof class, in order to be classified according to EN 13501-5.

Option 2: Products satisfying the requirements for the external fire performance, due to the deemed to satisfy list.

The roof covering is considered "deemed to satisfy" all the provisions for external fire performance of all national regulations of the Member States without the need for testing on the basis that it is included within the definitions given in Commission Decision 2000/553/EC and provided that any national provisions on the design and execution of works are fulfilled.

Option 3: Products classified without the need for further testing (CWFT)

The roof covering is considered to satisfy the requirements for performance Class of the characteristic external fire performance in accordance with the relevant EC Decision without the need for testing on the basis of its conformity with the specification of the product detailed in that Decision and its intended end use application being covered by that Decision.

5.2.4 Fire compartmentation

Fire compartmentation of a building is a function of its application and the regulations for Works in force in the Member State where the building is to be built (see boxed wording in the Foreword to this ETAG). The ETA will give details of the reaction to fire and resistance to fire of elements of the kit, such as internal walls. It is for the designer of the Works to determine their suitability and their position for particular buildings.

5.3 HYGIENE, HEALTH AND ENVIRONMENT

5.3.1 Vapour permeability and moisture resistance

Assessment shall be undertaken on the basis of calculations according to EN ISO 13788, taking into account the relevant design climatic conditions. This standard includes information on the assessment of the risk of mould growth.

The risk of condensation can normally be verified on the basis of hygrothermal characteristics of the products used in each component and the construction details.

Water vapour resistance of the relevant layers should be based upon:

- Design values given in EN 12524 or European technical specifications or
- Tests according to EN ISO 12572 or European technical specifications.

It should be noted that the permeability of some materials can vary dependent on whether they are drying up(absorption) or drying down(desorption) in a particular environment (hysteresis effects). This should be considered, particularly when using design values.

In addition, the design of joints and any fixings/services penetrating any vapour control element or membrane shall be assessed in relation to the risk of airborne moisture coming into contact with cold surfaces within the construction.

For verification of condensation risks due to low surface temperatures or air leaks see 5.6.1 and 5.6.2. Moisture resistance of materials in terms of durability is covered under 5.7.1.

It should be noted that the permeability of some materials can vary depending on whether they are drying up (absorption) or drying down (desorption) in a particular environment (hysteresis effects). This should be considered, particular when using design values.

It should be noted that some Member States have prescriptive requirements for the relative humidity in buildings and building elements (although it may be possible for materials to be accepted, based on an analyses of the system). This should be investigated by the Approval Body and the ETA applicant, in relation to the intended market.

5.3.2 Watertightness

5.3.2.1 External envelope

Water leakage resistance of the building envelope, including driving rain on facades and possibly snow penetration, shall primarily be assessed by the approval body on the basis of the standard construction details for the kit, and by using the available technical knowledge and experience from similar well-known technical solutions.

Note: The approval body should consider in his assessment all the climatic conditions to which the kit will be subjected depending on the market on which the kit will be put on.

The assessment of resistance against the penetration of driving snow into the external envelope may normally be based upon design or engineering knowledge e.g. as described in ETAG 022. The assessment shall include the full external envelope, including joints between prefabricated components in the kit and principal solutions for joints between the kit and the substructure.

If the resistance against weather influence cannot be assessed by the use of existing guideline (e.g. an ETAG), because of unfamiliar solutions to the relevant construction details, the approval body may find it necessary to require testing of the external envelope performance. Laboratory tests may be carried out according to EN 1027, EN 12155, EN 12865.

5.3.2.2 Internal surfaces

The performance of watertight membranes or surface layers in wet areas such as bathrooms, may be assessed on the basis of experience/technical knowledge Alternatively, it may be verified by reference to conformity with relevant performance standards or ETAG's for the products involved, e.g. product standards for roofing membrane systems. For products with unknown performance, verification can be according to the Nordtest methods NT BUILD 058, 230 and 448 (Watertight coverings for Bathrooms).

The primary purpose of the membrane is to ensure that the construction does not attain a moisture content such that damage, particularly in relation to durability, could occur. It should be noted that some Member States have prescriptive requirements for the vapour permeability of these membranes (although it may be possible for more permeable membranes to be accepted, based on an analysis of the system). This should be investigated by the Approval Body and the ETA applicant, in relation to the intended market.

5.3.3 Release of dangerous substances

5.3.3.1 Presence of dangerous substances in the kit

The applicant shall submit a written declaration stating whether or not the product/kit contains dangerous substances according to European and national regulations, when and where relevant in the Member States of destination, and shall list these substances.

5.3.3.2 Compliance with the applicable regulations

If the product/kit contains dangerous substances as declared above, the ETA will provide the method(s) which has been used for demonstrating compliance with the applicable regulations in the Member States of destination, according to the dated EU data-base (method(s) of content or release, as appropriate).

5.3.3.3 Application of the precautionary principle

An EOTA member has the possibility to provide to the other members, through the Secretary General, warning about substances which, according to Health authorities of its country, are considered to be dangerous under sound scientific evidence, but are not yet regulated. Complete references about this evidence will be provided.

This information once agreed upon, will be kept in an EOTA data base, and will be transferred to the Commission services.

The information contained in this EOTA data base will also be communicated to any ETA applicant.

On the basis of this information, a protocol of assessment of the product, regarding this substance, could be established on request of a manufacturer with the participation of the Approval Body which raised the issue.

5.4 SAFETY IN USE

5.4.1 Slipperiness of floor finishes

Verification of slip resistance of flooring materials shall be undertaken in accordance with the relevant EN-standards for the specified finished flooring products.

5.4.2 Resistance to eccentric loads including impact resistance

Mechanical resistance against dynamic loads shall primarily be assessed by the approval body on the basis of existing knowledge related to the intended use. Walls with well-known internal lining materials, such as standard gypsum boards, wood-based panel products and solid timber boards with studs, should generally be accepted to have a satisfactory impact resistance for normal use in, for example, dwellings and office buildings.

When the performance of the building is not known to be acceptable, or a quantified performance is to be declared due to national building regulations in some member states, the impact resistance should be tested. Testing of walls is to be carried out in accordance with EOTA Technical Report No 001: Determination of impact resistence of panels and panels assemblies.

Floors and roofs are tested according to EN 1195.

For wood-based panels used as loadbearing sub-floor panels on joists and as roof sheathing the impact resistance should be accepted as adequate when the panels conform to the requirements in EN 12871.

Where an approach is described in a relevant Eurocode, it will be acceptable to calculate impact resistance.

5.4.3 Falling due to changes in level or sudden drops

In the ETA the use category in relation to the mechanical resistance against dynamic loads of guard-rails, balustrades and parapets shall be given as meant in ETAG 003: 5.4.1.1 "Resistance of structural damage from soft body impact load – 50 kg bag".

5.5 PROTECTION AGAINST NOISE

5.5.1 Airborne sound insulation

The airborne sound insulation performance of the main building parts of an assembled kit shall be verified by either laboratory or field tests according to the relevant parts of EN ISO 140. The rating of airborne sound insulation shall be undertaken according to EN ISO 717.

Values for airborne sound insulation in completed buildings, based on laboratory tests, can be determined according to EN ISO 12354-1,-3,-4.

Indicative field testing of an assembly within a manufacturer's range may be possible, as part of the Approval process. However, National Regulations in some Member States may require field testing of the completed building in each case.

5.5.2 Impact sound insulation

The impact sound insulation performance of the floors of an assembled kit shall be verified by either laboratory or field tests according to the relevant parts of ISO EN 140, and the rating of impact sound insulation shall be done according to EN ISO 717.

Values for impact noise level in completed buildings, based on laboratory tests, shall be determined according to EN ISO 12354-2.

Indicative field testing of an assembly within a manufacturer's range may be possible, as part of the Approval process. However, National Regulations in some Member States may require field testing of the completed building in each case.

5.5.3 Sound absorption

Sound absorption is measured according to EN ISO 354.

5.6 ENERGY ECONOMY AND HEAT RETENTION

5.6.1 Thermal resistance

Thermal resistance (R-value) and the corresponding thermal transmittance (U-value) of the main building parts in a kit shall be calculated according to EN ISO 6946, using the design thermal conductivity values for materials according to EN 12524, relevant European product standards, or conductivity determined according to EN ISO 10456. Alternatively the thermal resistance may be verified by testing according to EN ISO 8990.

Verification of thermal transmittance for windows, doors and shutters may be undertaken by calculation according to EN 10077-1, EN ISO 10077-2 or by testing according to relevant EN ISO-standards for these products.

If the design has technical solutions with special thermal bridges not covered by the ordinary verification of the thermal resistance as mentioned above, the effect on the overall thermal resistance and the surface temperatures in relation to 4.3.1 shall be verified when the approval body finds this necessary. E.g. the effect of moisture due to thermal bridges. Such verification may be undertaken by calculations according to EN ISO 10211-1 and EN ISO 10211-2, or by testing according to EN ISO 8990 or relevant test standards for specific products.

5.6.2 Air permeability

The assessment of air permeability should be undertaken both with regard to energy economy (unintended ventilation), cold draughts (see 4.6.2) and risks of water vapour condensation inside the construction (see 4.3.1). The assessment must be undertaken on the basis of the intended use of the metal frame building kit, taking into account the internal and external design climates (e.g. geographical areas).

Assessment of the air permeability of the external envelope is normally undertaken by judgement of the construction details, on the basis of the knowledge and experience from traditional technical solutions. The assessment shall include joints between components.

When the approval body finds it necessary, e.g. when non-traditional joints are applied, the air permeability shall be verified by testing. Tests may be carried out by pressurisation of completed buildings according to EN 13829, or by laboratory testing according to prEN 1026, EN 12114 or other relevant test standards. The tests shall include long-term performance when relevant.

The assessment of air permeability should be undertaken both with regard to energy economy (unintended ventilation), cold draughts (see 4.6.2) and risks of water vapour condensation inside the construction (see 4.3.1). The assessment shall be undertaken on the basis of the intended use of the building kit, taking into account the internal and external design climates (e.g. geographical areas).

5.6.3 Thermal inertia

Verification of thermal inertia is undertaken on the basis of the following properties of the main building parts: the total mass per unit area, density and specific heat capacity of relevant materials and thermal resistance. Specific heat capacities are tabulated in EN 12524, and material densities are shown in ENV 1991-2-1.

Alternatively, values measured in accordance with ISO 11357-4 or equivalent may be used.

5.7 DURABILITY, SERVICEABILITY AND IDENTIFICATION

5.7.1 Aspects of durability

The estimated working life of the various parts of the kit will normally have to be determined by the approval body, on the basis of experience and general knowledge, and mainly by examining the building details which are part of the kit.

In so doing the approval body shall take into account the influence of climatic conditions when assessing the estimated working life of the metal frame building kit. The EC Guidance Paper F on Durability and the EOTA Guidance document 003 (Assessment of working life of products) may be consulted with regard to the use of relevant degradation factors and climatic sub-divisions of Europe.

When assessing the durability of materials and components in the kit it should be born in mind that durability is normally best ensured by good design measures and good site practice. Excessive moisture content should primarily be prevented by adequate construction details.

The most important aspect related to the durability of metal frame building kits is the corrosion of metal. Exposure classes are given in EN ISO 12944.

In general the rules given for the execution of steel structures given in ENV 1090 should be taken into account. The corrosion protection of steel structures should be carried out according to EN ISO 12944.

- The durability of materials and components in the kit is sufficiently proved if these
 materials and components comply with the relevant EN-, ETAG- or ISO standards.
- When a Eurocode standard is used for calculations, the materials and components shall comply with the requirements of the Eurocode and in particular with the material and components standards named in the Eurocode

5.7.2 Aspects of serviceability

Deflections and dynamic effects related to the structural design of the loadbearing elements shall be determined (serviceability limit state) by calculations or tests as in 5.1.

5.7.3 Identification

All components of the building unit shall be identified, either by reference to:

- Harmonised product standards;
- European Technical Approvals, based on other ETA-Guidelines;
- Non-harmonised European product standards;
- Non-harmonised International product standards;
- Descriptive identification, identifying the products by their composing materials and their function.

In any case, dimensions (length, width, thickness), geometry (squareness, flatness, ...), significant properties (mechanical, physical, chemical, ...) and their tolerances shall be given. In those cases where the above listed product specifications do not specify test methods for identification, test methods used shall be based on European standards (CEN), International standards (ISO), EOTA Technical Reports, UEAtc Guidelines, Nordtest standards or RILEM test methods.

Ultimately, a formulation, a ETA applicant's specific reference or a similar unique specification can also be accepted.

6 ASSESSING AND JUDGING THE FITNESS FOR USE

This chapter details the performance requirements to be met (chapter 4) in precise and measurable (as far as possible and proportional to the importance of the risk) or qualitative terms, related to the product and its intended use, using the outcome of the verification methods (chapter 5).

The performance characteristics are summarised in Table 3.

Where at least one Member State has no regulated requirement against a performance characteristic, or some aspect of that characteristic, then the 'No performance Determined' (NPD) option is available, exept for ER1. ER1 should always be evaluated. The ETA applicant and the Approval Body can agree where this option applies, taking account of the intended market. The ability of the Approval Body to determine performance in relation to regulated characteristics will be limited where the Unit(s) under assessment are 'incomplete' (See 2.1 Scope). This should be noted in the ETA but does not necessarily allow the use of the NPD option.

Table 3	3 - The type and options of produce		
ER	ETAG paragraph on product performance	Type of performance declaration in ETA's	
1	6.1 Mechanical Resistance and Stability	Characteristic values for materials orCharacteristic values for componentsCalculation methods	
2	6.2.1 Reaction to fire	- Classification according to Euroclasses in prEN 13501-1	
	6.2.2 Resistance to fire	- Classification according to prEN 13501-2 - Calculation methods	
	6.2.3 External fire performance of roof covering	- Classification according to prEN 13501-5	
	6.2.4 Fire compartmentation	- Classification statement for relevant elements	
3	6.3.1 Vapour permeability and moisture resistance	Assessed to be acceptable in relation to the intended use of the building and any limitations regarding climatic zones	
	6.3.2 Watertightness 6.3.2.1 External envelope 6.3.2.2 Internal surfaces	Assessed to be acceptable in relation to any limitations regarding climatic zones Assessed to be acceptable	
	6.3.3 Release of dangerous substances	- Declaration of dangerous substances defined in Council Directive 76/769/EEC, and possible measures to be taken	
4	6.4.1 Slipperiness of floors	- Assessed to be acceptable or - Slip resistance of flooring	
	6.4.2 Resistance to horizontal and ecccentric load	Assessed to be acceptable by judgement or measured horizontal soft and hard body impact resistance measured eccentric vertical load resistance	
	6.4.3 Falling due to changes in level or sudden drops	Assessed to be acceptable by judgement or measured horizontal hard body impact resistance of guard rails, balustrades and parapets	

ER	ETAG paragraph on product performance	Type of performance declaration in ETAs
5	6.5.1 Airborne sound insulation	 Weighted apparent sound reduction index for separating walls and floors Weighted apparent sound reduction index for all other walls and floors Weighted apparent sound reduction index for external walls and roof
	6.5.2 Impact sound insulation	 Weighted normalised impact sound pressure level for separating floors Weighted normalised impact sound pressure level for all other floors
	6.5.3 Sound absorption	- Sound absorption coefficient of internal surfaces
6	6.6.1 Thermal resistance	- Total thermal resistance R _t and corrected thermal transmittance U _c for: Exterior walls Windows and external doors Floors Internal walls Roof
	6.6.2 Air permeability	 Measured air leakage of type tested buildings and/or components or Assessed to be acceptable in relation to energy loss, cold draughts (ER3), interstitial or surface condensation (ER3), and intended use
	6.6.3 Thermal inertia	- Information on relevant data

No performance determined is **not** an option for the following

140 per	No performance determined is not an option for the following		
	6.7.1 Aspects of durability	- Assessed to be acceptable in relation to	
		intended use and the effect on performance	
		related to ER1 – ER6	
		- Possible conditions regarding maintenance	
	6.7.2 Aspects of serviceability	- Calculation methods	
	6.7.3 Identification	- Values of appropriate identification	
		parameters	

6.1 MECHANICAL RESISTANCE AND STABILITY

The properties of structural materials and components related to "mechanical resistance and stability" should be specified in the ETA as simply as possible with regard to the needs of fulfilling the National Provisions.

This may be done by expressing the properties in terms of:

- characteristic strength and other properties such as dimensions from which the loadbearing capacities of the assembled system installed in the works, taking into account the National Provisions, can be calculated, or
- design values provided that the NDPs applicable to works have been taken into account by appropriate levels and classes, which correspond to sets of NDPs.
- reference, in an unambiguous way, to the respective design documents of the works or to the drawings and material specifications linked to the client's order.

For further information: see the Guidance Paper L "Application and use of Eurocodes".

The ETA will state the calculation methods to be used for each individual building project in relation to the stability of the structure, taking into account the National Provisions.

6.2 SAFETY IN CASE OF FIRE

6.2.1 Reaction to fire

The individual kit components shall be classified according to EN 13501-1.

6.2.2 Resistance to fire

The metal frame building kit shall be classified according to the appropriate Part of EN 13501.

6.2.3 External fire performance of the roof covering

The roof covering shall be classified according to EN 13501-5.

6.2.4 Fire compartmentation

The ETA shall give details of the classification of elements, such as internal walls, so that the designer of the works can make use of this data when seeking to meet the regulatory requirements in force in the Member State in which the building is to be constructed.

6.3 HYGIENE, HEALTH AND ENVIRONMENT

6.3.1 Vapour permeability and moisture resistance

The product specifications shall be examined and performance, in respect of exposure to moisture.

assessed on the basis of known material properties, design details and the intended use. It shall be established that condensation in the structure as a result of water vapour diffusion will not occur or will occur only to an extent where damage is not caused during the condensation period and that the structure will dry out again during the evaporation period.

The assessment is to be undertaken with respect to both interstitial and internal surface condensation.

The performance of the kit is stated in the form of acceptable intended uses relevant to the design climatic conditions, e.g. types of buildings and geographical zones.

6.3.2 Watertightness

6.3.2.1 External envelope

The performance of the kit will normally have to be declared in qualitative terms in relation to the intended use like potential climatic zones, and with respect to durability aspects (see EC Guidance Paper F on Durability and the Construction Products Directive), as well as to the requirements mentioned in 4.3.2. When a kit is assessed to be inadequate in certain regions (for example in areas with exceptional amounts of driving rain or potential snow penetration), the limitations on the intended use shall be clearly stated in the ETA. In cases where tests have been performed, the test results shall be declared.

6.3.2.2 Internal surfaces

It shall be clearly indicated in the ETA which parts of the kit are classified as watertight surface areas.

6.3.3 Release of dangerous substances

The product/kit shall comply with all relevant European and national provisions applicable for the uses for which it is brought to the market. The attention of the applicant should be drawn to the fact that for other uses or other Member States of destination there may be other requirements which would have to be respected. For dangerous substances contained in the product but not covered by the ETA, additional national requirements might be applicable.

6.4 SAFETY IN USE

6.4.1 Slipperiness of floor finishes

When this performance is determined the slip resistance of finished floorings shall be declared according to the relevant standard for the specified flooring product.

6.4.2 Resistance to eccentric loads including impact resistance

Impact resistance can normally be declared as acceptable under defined conditions and not be quantified. Any limitations on intended use shall be stated in the ETA.

When wall structures have been tested according to EOTA TR: "Determination of impact resistance", and/or floors and roof according to EN 1195, or calculated according to the relevant Eurode, the determined impact resistance shall be declared in the ETA.

The minimum accepted impact resistance should normally be 100 Nm for soft body impact with the 50 kg bag and 10 Nm for hard body impact with the 1 kg steel ball, when the intended use is building units for residential housing, office buildings, etc. However, national building regulations in some member states require a minimum soft body impact resistance of 900 Nm for external walls.

Reference shall be made to Annex A of the EOTA Technical Report No 001 in order to determine the suitability of internal and external walls, for particular applications, in relation to their impact resistance.

6.4.3 Falling due to changes in level or sudden drops

In the ETA the use category in relation to the mechanical resistance against dynamic loads of guard-rails, balustrades and parapets shall be given as meant in ETAG 003: 6.4.1.1 "Resistance of structural damage from soft body impact load – 50 kg bag".

6.5 PROTECTION AGAINST NOISE

Sound insulation performance of building elements shall be declared in the ETA as estimated values for airborne sound insulation and impact noise level to be expected in completed buildings. The performance shall be specified with designations according to EN ISO 717, and should preferably be specified as given below. Other designations for the sound insulation performance mentioned in EN ISO 717 may be added in the approval, to agree with the verification methods according to national building regulations based on such designations.

6.5.1 Airborne sound insulation

The airborne sound insulation between rooms and of facades shall be declared in the ETA, as weighted apparent sound reduction index R'w, according to EN ISO 717-1. Other designations mentioned in EN ISO 717-1 may be added in the approval, to agree with the verification methods according to national building regulations based on such designations.

6.5.2 Impact sound insulation

The impact sound insulation for floors shall be declared in the ETA, as weighted normalised impact sound pressure level L'n w (band width 1/3 octave), according to EN ISO 717-2. Other designations mentioned in EN ISO 717-2 may be added in the approval, to agree with the verification methods according to national building regulations based on such designations.

6.5.3 Sound absorption

The sound absorption coefficient of internal surfaces is declared.

6.6ENERGY ECONOMY AND HEAT RETENTION

6.6.1 Thermal resistance

Thermal resistance values for each kind of building element (walls, floors, roofs) in the kit shall be declared as the total thermal resistance R_t in m^2K/W , including indicated surface resistances. For each kind of building element the thermal resistance shall be an average value, including the effect of studs, joists, plates, etc based on an average length in relation to one m^2 of the building part. Thermal resistance of windows and doors in the external envelope which are included in the kit shall be declared separately, also in the term m^2K/W .

The corresponding thermal transmittance shall be specified as the corrected thermal transmittance $U_c = 1/R_t + \Delta U$, where the correction term ΔU is calculated according to EN ISO 6946.

When significant thermal bridges are present, the thermal transmittance, in addition to the normal thermal transmittance U_c, shall be declared in units of W/m²K. If relevant, the potential surface condensation risk due to these thermal bridges shall be stated in the ETA (see 4.3.1).

6.6.2 Air permeability

Quantified national building regulations concerning air permeability are related to energy economy in the member states, although there may be no quantified requirements related to health and the effect on the indoor climate. Requirements on the overall air permeability are related to the completed building (works), and not to separate building parts.

Declaration of the degree of air permeability will normally have to be in qualitative terms, i.e. that a building based on the kit will result in adequate airtightness in relation to the intended use, incl. climatic zones, taking into account energy economy and heat retention, risk of cold draughts as mentioned in 4.6.2, and risk of condensation within the construction as mentioned in 4.3.1. When a kit is assessed to be inadequate in certain regions, the limitations on the intended use shall be clearly stated in the ETA.

If the completed air tightness has been measured, this value should be stated in relation to the measurement conditions.

6.6.3 Thermal inertia

The information on total mass per unit area of the main building parts, and on density, specific heat capacity and thermal resistance of relevant materials, shall be declared as a means for the designer to calculate the thermal inertia of the building in accordance with EN 832 (or prEN 13790).

6.7 DURABILITY, SERVICEABILITY AND IDENTIFICATION

6.7.1 Aspects of durability

The ETA shall declare that the durability of the kit is acceptable in relation to intended use and performances related to Essential Requirements 1 to 6.

Acceptable in the context of this ETAG means that, according to SECTION TWO, GENERAL NOTES, (d) Working life (durability) and serviceability, the assumed intended working life of the metal frame building kit for the intended use is 50 years for the loadbearing structure and non-accessible components and materials. For repairable or replaceable components and materials this working life is assumed 25 years

When relevant in the ETA also shall declare:

- · possible geographical limitations or climatic zones;
- · possible conditions regarding maintenance.

When applicable for properties related to the Essential Requirements "mechanical resistance and stability" or "resistance to fire" that have an influence on the durability of the works, the ETA shall give the possibility for national choices by means of levels or classes according to Guidance Paper E.

6.7.2 Aspects of serviceability

Maximum deflections at serviceability limit states, applied in the verification of structural capacities related to ER 1, shall be declared in the ETA, when this is relevant for the serviceability or to meet possible national regulations.

When relevant, the deflections and other serviceability requirements shall be declared in accordance with the rules given in the relevant Eurocode.

6.7.3 Identification

The appropriate identification parameters shall be given in the ETA. See also 9.1.

7 ASSUMPTIONS AND RECOMMENDATIONS UNDER WHICH THE FITNESS FOR USE OF THE METAL FRAME BUILDING KIT IS ASSESSED

7.1 GENERAL

This chapter sets out the assumptions and recommendations for design, installation and execution, packaging, transport and storage, use, maintenance and repair under which the assessment of the fitness for use according to the ETAG can be made (only when necessary and in so far as they have a bearing on the assessment or on the products).

7.2 DESIGN OF THE WORKS

7.2.1 Local building regulations

Normally a specification of relevant requirements concerning fire resistance and reaction to fire, sound insulation performance, thermal insulation performance and ventilation provisions shall be elaborated for each delivery as a basis for the production of a kit.

The design process (including the approval of detailed plans, applications for planning permissions, building permits, etc.) shall comply with the procedures foreseen in the Member States in which the building is to be built. An ETA for a metal frame building kit does not amend this process in any way.

7.2.2 Structural design

For each individual building project a structural design should be made. This structural design shall confirm that the structure of the building complies with the essential requirements 1, 2 and 6 as meant in chapter 6.

The structural design shall include specifications of any wind load anchors, welding and other supplementary structural works when these are not a part of the kit, but are essential for the fitness in use of the kit in the works.

The completed building (the works) shall comply with the building regulations (regulations on the works) applicable in the Member States in which the building is to be constructed. The procedures foreseen in the Member State for demonstrating compliance with the building regulations shall also be followed by the entity held responsible for this act. An ETA for a metal frame building kit does not amend this process in any way.

7.2.3 Substructure

The maximum required tolerances of the substructure dimensions, levelling should be assessed and permitted differential settlement of the fundation for the metal frame building kit, and be specified in the ETA.

Requirements concerning damp-proof membranes or other protection against moisture and resistance to Radon ingress from the substructure shall be specified.

7.2.4 Ventilation and heating

Buildings shall be assumed to be designed to have adequate ventilation rates and heating in relation to the intended use.

7.3 TRANSPORT, STORAGE

A manual for the transport and storage of the building kit shall be available from the ETA holder. The manual shall in particular cover requirements concerning handling equipment and transportation systems, and means and requirements for protecting the kit from weather exposure and mechanical damage during transportation. Reference to the manual shall be made in the ETA.

7.4 EXECUTION OF WORKS

General instruction for the installation of the kit in the works shall be available from the ETA holder. The instruction shall cover all important aspects related to the site work, such as:

- erection techniques and necessary equipment;
- temporary bracing and weather protection;
- completion of joints between kit components (structural fixing, welding, weather sealing etc.);
- fixing of wind anchorage and any seismic anchorage to the substructure and between main building parts;
- additional materials and components, including windows, roofs and cladding where relevant, applied on the site, and which are a precondition for the fitness of the assembled kit.

The requirements in EN 1090 should be taken in account when applicable.

As a supplement to the general instructions, specific instructions which contain special aspects related to each individual building project (e.g. special crane requirements, hoisting strap positions, etc) should normally be required. Reference to the instructions for installation of the kit shall be made in the ETA.

The completed building (the works) shall comply with the building regulations (regulations on the works) applicable in the Member States in which the building is to be constructed. The procedures foreseen in the Member State for demonstrating compliance with the building regulations shall also be followed by the entity held responsible for this act. An ETA for a metal frame building kit does not amend this process in any way.

7.5 MAINTENANCE AND REPAIR

It is normally assumed that regular maintenance will be required to retain performance and to obtain the estimated working life of the building. The type and frequency of such maintenance shall be specified, and shall be part of the assessment of the kit.

SECTION THREE: ATTESTATION OF CONFORMITY (AC)

8 EVALUATION AND ATTESTATION OF CONFORMITY AND CE MARKING

8.1 SYSTEM OF ATTESTION OF CONFORMITY

According to the decision 2003/728/EC of the European Commission the system(s) of attestation of conformity given in Table 4 applies.

Table 4 – System of attestation of conformity applicable to metal frame building kits

Product(s)	Intended use(s)	Level(s) or class(es)	Attestation of conformity system(s)
Metal frame building kits	In Building Works	Any	1

The system of attestation of conformity referred to above is defined as follows:

System 1: Certification of the conformity of the product by a notified certification body on the basis of:

- (a) Tasks for the manufacturer:
 - (1) factory production control;
 - (2) further testing of samples taken at the factory by the manufacturer in accordance with a prescribed test plan;
- (b) Tasks for the notified body:
 - (3) initial type-testing of the product;
 - (4) initial inspection of factory and of factory production control;
 - (5) continuous surveillance, assessment and approval of factory production control.

Note: In addition, in the case of system 1 of attestation of conformity, the manufacturer shall make a declaration of conformity of the product.

8.2 TASKS AND RESPONSIBILITIES OF THE MANUFACTURER AND NOTIFIED BODIES

8.2.1 Tasks for the manufacturer- control plan for FPC

Metal frame building kits may be manufactured using a wide variety of materials and design approaches. It is therefore not possible to prescribe exactly the actions to be undertaken by the manufacturer of metal frame building kits for FPC in the procedure of attestation. Table 5 shows an example of a control plan with the corner stones for a metal frame building kit. It is for the Approval Body and the ETA applicant to agree a control plan for the type of metal frame building kits under consideration. The objective is to ensure, by direct or indirect methods, that the product specification remains unchanged from that covered by the ETA, allowing for normal tolerances on material properties and manufacturing processes and that the performance of the metal frame building kits is consistent with the ETA holder's declaration, in relation to all the applicable essential requirements.

Table 7 - Control plan with the corner stones for the manufacturer of the metal frame building kit

		<u> </u>	1	T		
Subject/type of control	Test or control method	Criteria, if any	Minimum number of samples	Minimum frequency of control		
Factory production control (FPC)						
	cluding testing of samp	les in accordanc	e with a pre	scribed test plan]		
Laboratory and me	asurement equipment					
Equipment	Calibrating	Manufacturer declared accuracy	-	- On (re)installation - After major repair - Once per year		
Production equipm						
Drilling, welding, cutting and bending equipment	Visual inspection	Correct functioning	-	Daily		
Other production equipment	Visual inspection	Correct functioning	-	Weekly		
Incoming material						
Steel, stainless steel and aluminium	Check of inspection certificates according EN 10204	Certificates				
All materials	Inspection prior to discharge of delivery ticket and/or label on the package showing compliance with the order	Conformiy with the order	-	Each delivery		
All components	Inspection prior to discharge of delivery ticket and/or label on the package showing compliance with the order	Conformiy with the order	-	Each delivery		
Process inspection	ì					
Production of materials	Appropriate method	ETA holder's declaration	-	Depending on material and /or process		
Production of components	- Type - Quality - Mechanical properties - Dimensions - Tolerances - Test described in the product standard (e.g. prEN 1090)	Conformity with ETA specification or product standard	-	Depending on product and properties		
Finished product in			T	r -		
Metal frame building kit	- Visual inspection	Conformity with ETA specification	-	Every delivery		

In all cases, the Approval Body and ETA holder may agree alternatives to the test methods given or, where none is given, these parties may agree on the method.

8.2.2 Tasks for notified body

8.2.2.1 Initial type-testing of the product (ITT)

The corner stones of the actions to be undertaken by the notified body (bodies) in the procedure of attestation of conformity for metal frame building kits are laid down in table 6.

Table 6 - Control plan for the notified body (bodies) for metal frame building kits - corner stones

Initial type-testing of the product (ITT)

*All the characteristics to be verified for metal frame building kitswill have already been the subject of assessment or test by the ETA issuing body as part of the process of issuing the ETA. It is presumed that this data will be used by the ETA holder and notified body for validation purposes. The following list shows those tests and criteria that are related to the characteristics subject to Initial type Testing. *Note that in some instances the ETA holder may have chosen the npd option and ITT on these aspects is

not necessary or possible.

Characteristic of the Prefabricated Building Unit	ETAG paragraphs related to tests/assessment and criteria
ER1 Mechanical resistance and stability	5.1 and 6.1
ER2 Reaction to fire	5.2.1 and 6.2.1
Resistance to fire	5.2.2 and 6.2.2
Fire compartmentation	This characteristic can only be determined in relation to specific building designs. ITT should be based on confirmation of product design and specification.
ER3 Vapour permeability	5.3.1 and 6.3.1
Water tightness	5.3.2 and 6.3.2 Note that an assessment is permissible and therefore ITT should be based on confirmation of product design and specification.
Moisture resistance	5.3.1 and 6.3.1
Release of dangerous substances	5.3.3 and 6.3.3 ITT should be based on confirmation of product design and specification.
ER4 Slipperiness of floors	5.4.1 and 6.4.1, where the product specification includes a floor finish
Impact resistance	5.4.3 and 6.4.3
Falling due to changes of level or drops	5.4.2.and 6.4.2 ITT should be based on confirmation of product design and specification.
Resistance to eccentric loads	5.4.3 and 6.4.3
ER5 Airborne sound insulation	5.5.1 and 6.5.1
Sound absorption	5.5.2 and 6.5.2
Impact sound insulation	5.5.3 and 6.5.3
ER6 Thermal resistance	5.6.1 and 6.6.1
Air permeability	5.6.2 and 6.6.2
Thermal inertia	5.6.3 and 6.6.3

8.2.2.2 Initial inspection of factory and factory production control (FPC)

The initial inspection of the factory provides for the identification and documentation of the kind and manner of the manufacturing process and factory production control of the products. This is to enable the notified body/inspection body to assess the compliance with the provisions of the technical specification on the one hand and to provide a baseline to identify possible changes that may occur during surveillance.

An assessment shall be carried out of each production unit to demonstrate that the factory production control is in conformity with the ETA and any subsidiary information. This

assessment shall be based on an initial inspection of the factory, taking into account all the relevant provisions mentioned in 8.2.1. The relevant production units shall be specified in the ETA.

The factory production control shall include checks that the relevant design specifications for the production do exist, e.g. structural designs, construction details and manuals for installation as mentioned in chapter 7.

8.2.2.3 Continuous surveillance, judgement and assessment of factory production controle (FPC)

The surveillance of the manufacturing process includes checking the documentation of the factory production control to ensure continuing compliance with the provisions of the technical specification, and the identification of changes by comparing data obtained during the initial inspection or during the latest inspection.

8.3 CE MARKING AND ACCOMPANYING INFORMATION

According to Council Directive 93/68/EEC the CE marking consists of the letters "CE" in the form laid down in the Directive, followed by the identification number of the notified certification body, where applicable. For products subject to Council Directive 89/106/EEC the identification number of the notified certification body shall be given for metal frame building kits as Systems 1 applies.

The ETA shall indicate the information to accompany the CE-marking. According to the EC Guidance Paper D on CE-marking the required information to accompany the symbol "CE" is:

- Identification number of the notified body (A/C-system 1);
- Name / address of the manufacturer of the kit;
- Indication to clarify the intended use;
- Date of the marking;
- Number of the EC Certificate of Conformity (A/C-system 1);
- Number of ETA;
- Dangerous substances (see clause 5.3.3 of this ETAG).

The properties relating to the essential requirements "mechanical resistance and stability" or "resistance to fire", have to accompany the CE marking or a reference has to made, in an unambiguous way, to the respective design documents of the works (e.g. using a position number) on which the properties are mentioned.

Example of CE marking for a kit on the basis of an ETA:



1234

Any Company Street 1, City, Country

06

1234-CPD-0321

ETA-06/2135 ETAG 025

For the characteristics see document C1

Letters "CE"

Identification number of notified certification body

Name and address of the producer (legal entity responsible for the manufacture)

Two last digits of year of affixing CE marking

Number of EC certificate of conformity

ETA number

ETAG number

Type / intended use / characteristic(s) / declared values and/or classes in accordance with section(s) of the ETA

SECTION FOUR: ETA CONTENT

9 THE ETA CONTENT

9.1 THE ETA CONTENT

The ETA content shall be in accordance with the Commission Decision 97-571-EC, dated 22 July 1997. The following should be observed in addition:

9.1.1 Specification of materials

The materials and components which constitute the metal frame building kit shall be adequately identified, see 5.7.3.

The following table shows some <u>examples</u> of material specifications:

Table 7 – Examples of material specifications

Material/Component	Reference to product specifications such as:	
Structural steel		
Het relied Ler Heactions		
Hot rolled I or H sections Weldable structural steel	• EN 10025	
Dimensions	• EN 10023	
Hot rolled plates and flats	LIN 10034	
Weldable structural steel	• EN 10025	
Dimensions	• EN 10029	
Cold formed hollow square	211 10020	
sections		
Weldable steel	• prEN 10219-1	
Dimensions	• prEN 10219-2	
Fasteners		
Bolts	• ISO 4014	
Nuts	• ISO 4032	
Washers	• ISO 7089	
Welding consumables	EN 1090	
Corrosion protection	ENV 1090, EN ISO 12944	
Cladding and lining	Relevant product standards	
Sheathing		
Thermal insulation		
	Type and brand name, and/or relevant standards	
Water vapour and wind barriers	Type and brand name, and/or relevant product standards	
Roofing materials	Type and brand name, and/or relevant product standards	

9.1.2 Drawings

The ETA document shall include section drawings of the building parts. The purpose of the drawings is to illustrate the general build-up of the kit, i.e. structural system and loadbearing components, insulation layers, claddings etc. Material specifications may also be shown directly in these drawings of the kit.

In addition, the kit shall also be described by a set of construction details as specified in 9.1.8. These drawings shall be a formal part of the approval, but are presented in a supporting document and not in the ETA itself.

If required by the ETA-holder it should be allowed to keep some design details confidential by using neutral parts in the drawings, provided that the approval body does not find this in contradiction to necessary information related to the correct application of the kit and the evaluation of conformity performed by the approved body.

9.1.3 Product characteristics

The performances of the metal frame building kit related to the requirements and methods of verification and assessment mentioned in chapters 4, 5 and 6 shall be clearly stated. When a kit includes optional designs like a set of standard dimensions (thermal insulation thickness', loadbearing members etc.) it may be convenient to express the characteristics in table form.

The ETA shall include the following note:

"In addition to the specific clauses relating to dangerous substances contained in this European Technical Approval, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the EU Construction Products Directive, these requirements need also to be complied with, when and where they apply."

9.1.4 Storage and transport

Special provisions concerning storage and transport which are essential for the use of the kit shall be given in the ETA.

9.1.5 Erection details

The ETA shall include particular preconditions linked to the erection details of the metal frame system, which the approval body finds to be of special importance. This may be requirements related to the substructure, completion of element joints on site, wind load anchors, roof bracings, connection to services which might affect fire and sound separation etc (see also 7.4).

Reference to the manufacturer's general erection manual shall be made.

9.1.6 Estimated working life

The minimum estimated working life of the metal frame building kit shall be stated.

9.1.7 Maintenance

Basic maintenance to obtain the minimum estimated working life of the metal frame building kit shall be specified (see also 7.5).

9.1.8 Supporting documents

A set of drawings showing the essential construction details of the kit shall form a supporting document as a formal part of the ETA. The purpose of this document is to provide the necessary detailed description of the metal frame building kit, including the assembly details on site and the conditions for the installation of the kit in the works. The current version of this document shall at all times be kept by the approval body and the approved inspection body.

The set of construction details shall describe the general design of the building kit, including joints between main building parts and joints related to integrated components. The detail drawings shall form the necessary documentation for assessing all the performance requirements specified in chapter 4, including weather resistance and air permeability.

Only the most essential construction details, which are directly related to the main building parts, and which are the pre-designed standard details for the kit, shall be included. Any restrictions for methods and locations of the connections of the components which are not part of the kit (such as external envelope, internal partitions, roofs etc.) shall be given in the supporting documents.

9.2 ADDITIONAL INFORMATION

It shall be stated in the ETA whether or not any additional (possibly confidential) information shall be supplied to the approved body for the attestation of conformity.

ANNEX A

COMMON TERMINOLOGY AND ABBREVIATIONS

For the meaning of these terms see EOTA document "Common terms used in Guidelines for European Technical Approval" published on the EOTA website (www.eota.be).

ANNEX B

LIST OF REFERENCE DOCUMENTS

Verification of loadbearing capacity

EN 1990-1:2002: Basis of structural design

EN 1991-1-1:2002: Eurocode 1: Actions on structures – Part 1-1- General actions – Densities, self weight, imposed loads for buildings

EN 1991-2-3:1999 Eurocode 1: Basis of design and actions on structures – Part 2-3: Actions on structures – Snow loads

ENV 1991-2-4:1995 Eurocode 1: Basis of design and actions on structures – Part 2-4: Actions on structures – Wind actions

EN 1993 1-1:2006 Eurocode 3: Design of steel structures – Part 1-1: General rules and rules for buildings

EN 1998-1:2005 Eurocode 8: Design of structures of earthquake resistance – Part 1: General rules, seismic actions and rules for buildings.

ENV 1999 1-1:1998 Eurocode 9: Design of aluminium structures – Part 1-1: General rules and rules for buildings

Verification of fire resistance and reaction to fire

EN 1991-1-2:2002 General actions – Actions on structures exposed to fire.

EN 1993 1-2:2001 Eurocode 3: Design of steel structures – Part 1-2: General rules – Structural fire design

ENV 1999 1-2:1998 Eurocode 9: Design of aluminium structures – Part 1-2: General rules – Structural fire design

EN 13501-1:2003 Fire classification of construction products and building elements – Part 1: Classification using data from reaction to fire tests

EN 13501-2:2004 Fire classification of construction products and building elements – Part 2: Classification using data from resistance to fire tests (excluding products for use in ventilation systems)

EN 13501-5:2002 Fire classification of construction products and building elements: Classification using test data from external fire exposure to roof tests.

Verification of water vapour permeability and moisture resistance

EN 12572:2001 Hygrothermal performance of building materials and products - Determination of Water Vapour Transmission Properties (ISO/FDIS 12572:2000)
EN 13788:2001 Hygrothermal performance of building components and building elements – Internal surface temperatures to avoid critical surface humidity interstitial condensation - Calculation method.

Verification of watertightness

EN 1027:2000 Windows and doors - Water tightness - Test method

EN 12155:2000 Curtain walling - Water tightness - Laboratory test under static pressure

EN 12865:2001 Hygrothermal performance of buildings components and elements -

Determination of resistance to driving rain under pulsating air pressure

Verification of safety in use

EN 1195:1998 Deck safety harness and safety line for use on recreational craft – Safety requirements and test methods.

ISO 7892:1988 Vertical Building Components - Impact Resistance - Impact Bodies and general Test Procedures

ISO/DIS 7893:1990 Performance Standards in Building - Partitions made from Components - Impact Resistance Tests

EN 12871: 2001 Wood based panels – Performance specifications and requirements for load bearing boards for use in floors, walls and roofs.

Verification of sound insulation performance

ISO 140-4:1998 Acoustics - Measurement of sound insulation in buildings and of building elements – Part 4: Field measurements of airborne sound insulation between rooms ISO 140-5:1998 Acoustics - Measurement of sound insulation in buildings and of building elements – Part 5: Field measurements of airborne sound insulation of facade elements and facades

ISO 140-7:1998 Acoustics - Measurement of sound insulation in buildings and of building elements – Part 7: Field measurements of impact sound insulation of floors

ISO 354:2003 Acoustics - Measurement of sound absorption in reverberation room

ISO 717-1:1996 Acoustics - Rating of sound insulation in buildings and of building elements - Part 1: Airborne sound insulation

ISO 717-2:1996 Acoustics - Rating of sound insulation in buildings and of building elements - Part 2: Impact sound insulation

prEN 12354-1:2000 Building acoustics - Estimation of acoustic performance of buildings from the performance of elements – Part 1: Airborne sound insulation between rooms

prEN 12354-2:2000 Building acoustics - Estimation of acoustic performance of buildings from the performance of elements – Part 2: Impact sound insulation between rooms

prEN 12354-3:2000 Building acoustics - Estimation of acoustic performance of buildings from the performance of elements – Part 3: Airborne sound insulation against outdoor sound

EN 12354-4 Building acoustics- Part 4: Estimation of acoustic performance of buildings from the performance of elements: transmission of indoor sound to the outside.

Verification of thermal insulation

EN ISO 6946:1996 Building components and building elements - Thermal resistance and thermal transmittance- Calculation method (ISO 6946:1996)

EN ISO 8990:1997 Thermal insulation – Determination of steady-state thermal transmission – Calibrated and guarded hot box (ISO 8990:1994)

EN ISO 10077-1:2004 Thermal performance of windows, doors and shutters – Calculation of thermal transmittance – Part 1: Simplified method

EN ISO 10211-1:1995 Thermal bridges in building construction - Heat flows and surface temperatures –Part 1: General calculation methods (ISO 10211-1:1995)

prEN ISO 10211-2:2001 Thermal bridges in building construction - Heat flows and surface temperatures –Part 2: Calculation of linear thermal bridges (ISO/FDIS 10211-2:1999)

EN ISO 10456:1999 Thermal insulation - Building materials and components - Determination of declared values and design thermal values

EN 12524:2000 Building materials and products – Hygrothermal properties – Tabulated design values

Verification of air permeability

ISO 9972:1996 Thermal insulation - Determination of building airtightness - Fan pressurisation method

EN 1026:2000 Windows and doors - Air permeability - Test method

EN 12114:2000 Thermal performance of buildings - Air permeability of building components and building elements – Laboratory test method

Execution of works

EN 1090-1: 2004 Steel and aluminium components- General delivery conditions

Execution of works

EN 10204: 2004 Metallic products – Types of inspection documents